

**13<sup>th</sup> NATIONAL CERTIFICATION EXAMINATION**  
**FOR**  
**ENERGY AUDITORS – September, 2012**

**PAPER – 4: Energy Performance Assessment for Equipment and Utility Systems**

**Date: 16.9.2012 Timings: 14:00-16:00 HRS Duration: 2 HRS Max. Marks: 100**

**Section - I: BRIEF QUESTIONS**

**Marks: 10 x 1 = 10**

- (i) Answer all **Ten** questions
- (ii) Each question carries **One** mark

S-1	A draft system in a boiler which uses both FD and ID fan is called.....
Ans	Balanced Draft
S-2	In a vapour compression refrigeration system, why the heat rejected in the condenser is more than the heat absorbed in the evaporator ?
Ans	Because heat of compression is also added to it
S-3	If the unit heat rate is 3191 kcal/kWh and the turbine heat rate is 2808 kCal/kWh what is the boiler efficiency ?
Ans	$(2808/3191) \times 100 = 88 \%$
S-4	A rise in conductivity of boiler feed water indicates ____ .
Ans	Rise in the TDS level of feed water
S-5	Why is it preferable to measure the flow at the inlet side of the fan?
Ans	Less turbulence
S-6	The critical point of steam occurs at ____bar and _____ °C
Ans	221.2 bar and 374.15°C
S-7	In a heat exchanger _____ is the ratio of actual heat transfer rate to the maximum heat transfer rate.

Ans	Effectiveness
S-8	In an integrated steel plant pig iron is produced from _____ furnace?
Ans	Blast furnace
S-9	PLF of a 210 MW power plant is 85% , what is the annual gross generation in MWh
Ans	1,563,660 MWH
S-10	A pump operates on water with a total head of 10 m. If water is replaced by ethylene glycol with a specific gravity of 1.12 what will be the total head developed by the pump ?
Ans	10 m

..... **End of Section - I** .....

**Section - II: SHORT NUMERICAL QUESTIONS**

**Marks: 2 x 5 = 10**

- (i) Answer all **Two** questions
- (ii) Each question carries **Five** marks

<b>L-1</b>	Calculate pressure drop in meters when pipe diameter is increased from 250 mm to 300 mm for a length of 600 meters. Water velocity is 1.5 m/s in the 250 mm diameter pipe and friction factor is 0.005 for both the pipes.
Ans	$\text{Pressure drop} = \frac{4fLV^2}{2gD}$ <p>Velocity of water in pipe of 300 mm diameter = <math>(0.25 \times 0.25 \times 1.5) / (0.3 \times 0.3)</math> = 1.04 m/s</p> <p>Pressure drop with 300 mm = <math>4 \times 0.005 \times 600 \times 1.04^2 / (2 \times 9.81 \times 0.300)</math> = 2.2 m</p>
<b>L-2</b>	A three phase 37 kW four pole induction motor operating at 49.8 Hz is rated for 415 V, 50 Hz and 1440 RPM. The actual measured speed is 1480 RPM. Find out the percentage loading of the motor if the voltage applied is 410 V.
Ans	$\% \text{ Loading} = \frac{\text{Slip}}{(S_s - S_r) \times (V_r / V)^2} \times 100\%$

	<p><b>Synchronous speed = <math>120 \times 49.8 / 4 = 1494</math> rpm</b></p> <p><b>Slip = Synchronous Speed – Measured speed in rpm.</b>  <b>= <math>1494 - 1480 = 14</math> rpm.</b></p> <p><b>% Loading = <math>\frac{14}{(1494 - 1440) \times (415/410)^2} \times 100\% = 25.8 \%</math></b></p>
--	--

..... **End of Section - II** .....

**Section - III: LONG NUMERICAL QUESTIONS**

**Marks: 4 x 20 = 80**

- (i) Answer all **Four** questions
- (ii) Each question carries **Twenty** marks

N-1	KEY
	<p>a) Theoretical air required for complete combustion</p> $= \frac{(11.6 \times C) + \left\{ 34.8 \times \left( H_2 - \left( \frac{O_2}{8} \right) \right) \right\} + (4.35 \times S)}{100}$ $= \frac{(11.6 \times 33.95) + \left\{ 34.8 \times \left( 5.01 - \left( \frac{32.52}{8} \right) \right) \right\} + (4.35 \times 0.09)}{100} = 4.27 \text{ kg / kg of paddy husk}$ <p>Moles of N<sub>2</sub> = <math>\frac{4.27 \times \left( \frac{77}{100} \right)}{28} + \left( \frac{0.0091}{28} \right) = 0.1178</math></p> <p>% CO<sub>2</sub> theoretical = <math>\frac{\text{Moles of C}}{\text{Moles of N}_2 + \text{Moles of C} + \text{Moles of S}}</math></p> $= \frac{\left( \frac{0.3395}{12} \right)}{0.1178 + \left( \frac{0.3395}{12} \right) + \left( \frac{0.0009}{32} \right)}$

Max theoretical (CO <sub>2</sub> ) <sub>t</sub>	=	19.36 %
Actual CO <sub>2</sub> measured in flue gas	=	14.0%
b) % Excess air supplied	=	$\frac{7900 \times [(CO_2)_t - (CO_2)_a]}{(CO_2)_a \times [100 - (CO_2)_t]} = 37.5 \%$
c) Actual mass of air supplied	=	{1 + EA/100} x theoretical air
	=	{1 + 37.5/100} x 4.27
	=	5.87 kg/kg of coal
Mass of dry flue gas=		$\frac{0.3395 \times 44}{12} + 0.0091 + \frac{5.87 \times 77}{100} + \frac{(5.87 - 4.27) \times 23}{100}$
	=	6.15 kg / kg of coal
<b>(or)</b>		
(actual mass of air supplied + 1) – mass of H <sub>2</sub> O		
(5.87 + 1) – (9H + M) = 6.87 – (9x.05 + 0.1079) = 6.87 – 0.5579 = 6.31 kg/kg of coal		
% Heat loss in dry flue gas	=	$\frac{m \times C_p \times (T_f - T_a)}{GCV \text{ of fuel}} \times 100$
	=	$\frac{6.15 \times 0.23 \times (140 - 32)}{3568} \times 100$
	=	<b>4.28 %</b>
Loss due to CO	=	$\frac{\%CO \times C}{\%CO + \%CO_2} \times \frac{5654}{GCV \text{ of fuel}} \times 100$
	=	$\frac{0.35 \times 0.3395}{(0.35+14)} \times 5654$
	=	1.31 %
Heat Loss in ash		
% heat loss due to unburnt flyash		
% ash in paddy husk	=	16.73
Ratio of bottom ash to flyash	=	10:90

	<p>GCV of flyash = 450 kcal/kg</p> <p>Amount of flyash in 1 kg of husk = <math>0.9 \times 0.1673</math> = 0.15 kg</p> <p>Heat loss in flyash = <math>0.15 \times 450</math> = 67.5 kcal/kg of husk</p> <p>GCV of bottom ash = 800 kcal/kg</p> <p>Amount of bottom ash in 1 kg of husk = <math>0.1 \times 0.1673</math> = 0.01673 kg</p> <p>Heat loss in bottom ash = <math>0.01673 \times 800</math> = 13.4 kcal/kg of husk</p> <p>Total heat loss in ash = <math>67.5 + 13.4</math> = 80.9 kcal/kg</p> <p>% loss in ash = <math>80.9/3568</math> = 2.26 %</p> <p>Total losses = <math>100 - (4.28 + 1.31 + 2.26) - (14.33)</math></p> <p>Boiler efficiency = <math>100 - 7.85 - 14.33 = 78 \%</math></p>
<b>N-2</b>	<b>KEY</b>
Ans	<p>Hot Water use per day : 20,000 L/day</p> <p>Water in = 20°C          Water out = 60°C          Temp. diff. = 40°C</p> <p>Total Heat required = <math>mCpdt</math>          = <math>20000 \times 1 \times 40 = 8,00,000</math> kcal/day</p> <p>a) <u>Energy Requirement for 20KL/day of water for a temperature differential of 40 deg.C in an Electric Boiler/Geyser</u></p> <p>Energy Requirement (for 20 KL/day)          = <math>\frac{\text{Total heat required (800000)}}{860 \text{ kcal/kWh} \times 0.99 \text{ (efficiency of electric heating)}}</math>          = 939.6 kWh/day</p> <p>b) <u>For 20 KL/day, of water flow with 40°C Temperature Diff. Energy to be drawn by Heat Pump</u>          = <math>\frac{8,00,000}{860 \times 0.95 \times 2.5} = 391.68</math> Kwh/day</p>

	<p>Energy drawn by circulation pump = 2.8 x 24 hr = 67.2 kWh/day</p> <p>Energy drawn by evaporator fan = 1.4 kW x 16 hr = 22.4 kWh/day</p> <p>Total Energy drawn by heat pump system = 391.68 + 67.2 + 22.4 = 481.28 kWh /day</p> <p><u>SAVINGS IN COMPARISON TO ELECTRIC WATER HEATER</u></p> <p>= 939.6 – 481.28 = 458.32 Kwh/day = 1,60,412 kWh/year ( @ 350 days/year) = 12.83 lakhs ( @ Rs8.0 per kWh)</p> <p>SIMPLE PAY BACK PERIOD = Rs.16.0 LAKHS Investment/ Rs.12.83 lakhs per year savings = 1.25 years or 15 months</p>
<b>N-3</b>	<b>KEY</b>
Ans	<p>Power generation from cogen plant = 5000 X 0.9 X 8000 = 360 lac Kwh/yr</p> <p>Auxiliary power = 1%</p> <p>Net power generation = 0.99 X 360 = 356.4 lac Kwh</p> <p>Natural gas requirement for power generation = 360 X 3050 / 9500 = 115.57 lac sm<sup>3</sup></p> <p>Cost of fuel per annum = 115.57 X 8 = Rs.924.56 lacs</p> <p>Annual expenditure for interest, depreciation and O&amp;M = 500 + 200 = 700 lacs</p> <p>Total cost of generation = Rs.1624.56 lacs.</p> <p>Cost of cogeneration power = 1624.56 X 10<sup>5</sup> / 356.4 X 10<sup>5</sup> = Rs.4.56 / Kwh.</p> <p>Gas consumption in existing gas fired boiler = [10000 (665 – 85) / (0.82 X 9500)] = 744.6 Sm<sup>3</sup>/hr = 744.6 x 24 = 17870 sm<sup>3</sup>/day</p>

	Cost of steam from existing boiler = $744.6 \times \text{Rs. } 8 \times 8000$ = Rs. 476.5 Lacs /yr  Cost of power generation after giving credit for steam generation = $1624.56 - 476.5 = \text{Rs. } 1148.06 \text{ lacs}$  Cost of power generation after accounting for steam cost = $1148.06 \times 10^5 / 356.4 \times 10^5$ = Rs. 3.22 / kWh  Grid power cost = Rs. 4.5 / Kwh Cost advantage for cogen plant generation = $4.5 - 3.22 = \text{Rs. } 1.28 / \text{Kwh}$  Daily gas requirement for operating GT cogen plant = $\frac{5000 \times 0.9 \times 3050 \times 24}{9500}$ = $34673.68 \text{ Sm}^3 / \text{day}$  Additional gas requirement for co-gen plant = $34673.68 - 17870 = 16803.68 \text{ Sm}^3/\text{day}$
--	--

**N-4** To attempt **ANY ONE OF THE FOLLOWING** among A, B, C and D

**N4A** **KEY**

Ans	i) Turbine power output kW = $\frac{\text{Steam flow to turbine kg/hr} \times \text{enthalpy drop across the turbine kcal/kg}}{860}$ Inlet enthalpy of steam = 794.4 kcal/kg  Enthalpy of exhaust steam is calculated as given below exhaust steam dryness fraction = 90% enthalpy of exhaust steam = $(45.9 + 0.9 \times 572.5) = 561 \text{ kcal/kg}$ turbine output = $((120 \times 1000 \text{ kg/hr} \times (794.4 - 561) \text{ kcal/kg}) / 860)$ turbine output = 32567.4 kW  ii) generator output kW = turbine output x combined efficiency of mechanical, gear transmission & generator $= 32567.4 \times 0.92$ $= 29962 \text{ kW}$  iii) turbine heat rate = heat input in to the turbine/ generator out put $= q \times (h_1 - h_w) / \text{generator out put}$
-----	--

	<p>Where <math>q</math> = steam inflow to turbine kg/hr  <math>h_1</math> = enthalpy of turbine inlet steam = 794.4 kcal/kg  <math>h_w</math> = enthalpy of feed water to boiler = 100 kcal/kg</p> <p>Turbine heat rate = <math>((120 \times 1000 \text{ kg/hr}) \times (794.4 - 100) \text{ kcal/kg}) / 29962 \text{ kw}</math>  <math>= 2781 \text{ kcal/kwh}</math></p> <p>iv) unit heat rate = turbine heat rate / boiler efficiency  <math>= 2781 / 0.88 = 3160 \text{ kcal/ kwh}</math></p> <p>v) turbine cycle efficiency = <math>(860 / \text{turbine heat rate}) \times 100</math>  <math>= 860 / 2781 = 0.309</math>  <math>= 0.309 \times 100 = 30.9\%</math></p> <p>vi) condenser heat load = <math>m \times c_p \times dt</math></p> <p>Where <math>m</math> = cooling water flow through condenser, kg/hr</p> <p>note: density of water is given as 0.95 g /cubic centimetre = 950 kg/ cubic meter  <math>c_p</math> = specific heat of cooling water, kcal/ kg. °C = 0.98 kcal /kg. °C  <math>dt</math> = cooling water temperature rise, °C = 10</p> <p>Condenser heat load = <math>6318 \times 950 \times 0.98 \times 10 = 5,88,20,580 \text{ kcal /hr}</math></p> <p>vii) specific steam consumption of turbine = <math>860 / (\text{enthalpy drop} \times \text{combined efficiency})</math>  <math>= 860 / ((794.4 - 561) \times 0.92)</math>  <math>= 860 / (233.4 \times 0.92) = 4.0 \text{ kg/kwh}</math>  <math>= 4.0 \text{ kg / kwh}</math></p>
<b>N4B</b>	<b>KEY</b>
Ans	<p>Volumetric flow rate of PH gas at <b>NTP</b> = <math>1.47 \times 125 \times 1000 = 183750</math> [Nm<sup>3</sup>/hr]</p> <p>Mass flow rate of PH gas = <math>183750 \times 1.42 = 260925</math> [kg/hr]</p> <p><u>Calculation for 4 stage pre-heater kiln</u></p> <p>Heat loss in PH Gas = <math>m \times c_p \times T</math> [kcal/hr]</p> <p><math>= 260925 \times 0.244 \times 370 = 23556309</math> [kcal/hr]</p> <p>Equivalent coal wasted = <math>\frac{23556309}{5540 \times 1000} = 4.252</math> [tons of coal/hr]</p> <p>Electrical Energy consumption of PH Fan</p>

3 Marks



<p>Volumetric flow rate of PH Gas at 370°C temperature and -400 mm WC static pressure:</p> $V = 183750 \times \frac{(273 + 370) \times 10333}{273 \times (10333 - 400)} = 450216 \quad [\text{m}^3/\text{hr}]$ <p>or <math>V = 450216/3600 = 125 \quad [\text{m}^3/\text{sec}]</math></p> <p>Pressure difference across PH fan = 50 – (- 400) = 450 [mm WC]</p> <p>Power consumption of PH fan</p> $P = \frac{125 \times 450}{102 \times 0.72 \times 0.95} = 806.24 \quad [\text{kW}]$ <p><u>Calculation for 6 stage pre-heater kiln</u></p> <p>Heat loss in PH Gas = m x cp x T [kcal/hr]              = 260925 x 0.244 x 295 = 18781381 [kcal/hr]</p> <p>Equivalent coal wasted = <math>\frac{18781381}{5540 \times 1000} = 3.39</math> [tons of coal/hr]</p> <p>Electrical Energy consumption of PH Fan</p> <p>Volumetric flow rate of PH Gas at 295 °C temperature and -600 mm WC static pressure:</p> $V = 183750 \times \frac{(273 + 295) \times 10333}{273 \times (10333 - 600)} = 405875 \quad [\text{m}^3/\text{hr}]$ <p>Or <math>V = 405875/3600 = 112.75 \quad [\text{m}^3/\text{sec}]</math></p> <p>Pressure difference across PH fan = 50 – (- 600) = 650 [mm WC]</p> <p>Power consumption of PH fan</p> $P = \frac{112.75 \times 650}{102 \times 0.72 \times 0.95} = 1050.4 \quad [\text{kW}]$ <p>The above kilns can be compared as follows:</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th>Item</th> <th>6 Stage PH Kiln</th> <th>4 stage PH kiln</th> </tr> </thead> <tbody> <tr> <td><b>PH Gas heat loss (kcal/hr)</b></td> <td><b>18781381</b></td> <td><b>23556309</b></td> </tr> <tr> <td><b>Equivalent coal wasted (tons of coal)</b></td> <td><b>3.39</b></td> <td><b>4.252</b></td> </tr> <tr> <td><b>Power consumption in PH Gas (kW)</b></td> <td><b>1050</b></td> <td><b>806.24</b></td> </tr> </tbody> </table> <p>Calculation for annual Monetary savings</p> <p>Coal savings in 6 stage PH Kiln = 4.252 – 3.39 = 0.862 [ton of coal/hr]</p> <p>Annual monetary savings (Thermal) = 0.862 x 8000 x 6150 = 4,24,10,400 [Rs.]</p> <p>Additional Electrical energy requirement for 6 stage PH Kiln = 1050.4 – 806.24 = 244.16 [kW]</p> <p>Annual additional electrical cost = 244.16 x 8000 x 5 = 97,66,400 [Rs.]</p> <p>It is obvious that in monitory terms, thermal energy saving in 6 stage pre-heater kiln is higher than the additional electrical energy cost in 4 stage kiln. Therefore, 6 stage pre-heater kiln is better option than 4 stage pre-heater</p>			Item	6 Stage PH Kiln	4 stage PH kiln	<b>PH Gas heat loss (kcal/hr)</b>	<b>18781381</b>	<b>23556309</b>	<b>Equivalent coal wasted (tons of coal)</b>	<b>3.39</b>	<b>4.252</b>	<b>Power consumption in PH Gas (kW)</b>	<b>1050</b>	<b>806.24</b>
Item	6 Stage PH Kiln	4 stage PH kiln												
<b>PH Gas heat loss (kcal/hr)</b>	<b>18781381</b>	<b>23556309</b>												
<b>Equivalent coal wasted (tons of coal)</b>	<b>3.39</b>	<b>4.252</b>												
<b>Power consumption in PH Gas (kW)</b>	<b>1050</b>	<b>806.24</b>												

	<p>kiln.</p> <p>So the net annual monetary saving in case of 6 stage pre-heater kiln is  <math display="block">= 4,24,10,400 - 97,66,400 = 3,26,44,000</math> [Rs.]</p>
<b>N4C</b>	<b>KEY</b>
Ans	<p><b>a)</b>  <u><b>Before insulation</b></u>          Surface heat loss, <math>S = [10 + (TS - Ta)/20] \times (Ts - Ta)</math>          Total heat Loss = <math>S \times A</math> where A= Surface area, <math>m^2</math>          Surface heat loss, <math>S = [10 + (110 - 25)/20] \times (110 - 25) = 1211.25 \text{ K.Cal}/m^2/hr</math>          Total heat loss = <math>1211.25 \times 20 \text{ m}^2 = 24225 \text{ kCal}/hr</math></p> <p><u><b>After insulation</b></u>          Surface heat loss, <math>S = [10 + (55 - 25)/20] \times (55 - 25) = 345 \text{ K.Cal}/m^2/hr</math>          Total heat loss = <math>345 \times 20 \text{ m}^2 = 6900 \text{ kCal}/hr</math>          Heat reduction per hour after proper insulation = <math>24225 - 6900 = 17325 \text{ kCal}/hr</math>          Annual heat loss reduction = <math>17325 \times 8000 = 138600000</math>  <math>= 138.6 \text{ million kCal}/year</math></p> <p>Steam distribution loss = 20%          Heat loss = <math>138.6 \text{ million kCal} / 0.8 = 173.25 \text{ million kcal}/year</math></p> <p>Boiler efficiency = 70%          Equivalent coal consumption reduction = <math>173.25 \times 10^6 / 0.7 \times 4800 = \mathbf{51.56 \text{ Ton /year}}</math>          Monetary Cost savings per year = <math>51.5 \times 5000 = \mathbf{Rs 2.575 \text{ lacs}}</math></p> <p>Investment @ Rs 1000 per <math>M^2</math> = <math>20 \times 1000 = \mathbf{Rs 20000}</math></p> <p><u><b>Condensate recovery</b></u>          Reduction in coal consumption through heat recovered from condensate return = <math>2000 \times 1 \times (80 - 40) / 0.7 \times 4800</math>  <math>= 23.8 \text{ kg of coal per hour}</math>          Annual coal savings = <math>23.8 \times 8000/1000</math>  <math>= \mathbf{190.4 \text{ ton / year}}</math>          Annual savings = <math>23.8 \times 8000 \times \text{Rs.}5/\text{kg coal}</math>  <math>= \mathbf{Rs. 9.52 \text{ lacs}}</math></p> <p><b>b) Simple payback period</b>          Total savings from both the measures = <math>2.575 + 9.52 = 12.1 \text{ lakhs}</math>          Total investment = <math>\text{Rs. } 20,000 + \text{Rs } 2 \text{ lakhs} = \mathbf{Rs. 2.2 \text{ lakhs}}</math>          Simple payback period (combined) = <math>2.2/12.1 = 2.2 \text{ months}</math></p> <p><b>c) GHG emission reduction</b>          Carbon content in the coal = 40% by weight</p>

	<p>Total Coal saving /year = 51.5 + 190.4 = 241.9 Ton per year</p> <p>CO<sub>2</sub> reduction = 241.9 x 0.4 x 44/12 = 355 Ton of CO<sub>2</sub>/year</p>
<b>N4D</b>	<b>KEY</b>
Ans	<p>Theoretical air required for complete combustion</p> $= [(11.6 \times 85.9) \times (34.8 \times (12 - 0.7/8)) + 4.35 \times 0.5] / 100$ $= 996.44 + 414.12 + 2.175 / 100$ <p><b>= 14.1 kg/kg of oil</b></p> <p>Existing oxygen % in flue gas = 6%</p> <p>% excess air supplied = <math>6 \times 100 / (21 - 6) = 40\%</math></p> <p>Actual mass of air supplied = <math>(1 + \text{Excess air}/100) \times \text{Theoretical air}</math></p> $= (1 + 40/100) \times 14.1$ <p><b>= 19.74 kg/kg of oil</b></p> <p>After modification, oxygen % in flue gas = 3%</p> <p>% excess air supplied = <math>3 \times 100 / (21 - 3) = 16.67\%</math></p> <p>Actual mass of air supplied = <math>(1 + \text{Excess air}/100) \times \text{Theoretical air}</math></p> $= (1 + 16.67/100) \times 14.1$ <p><b>= 16.45 kg/kg of oil</b></p> <p><b><u>a) Heat loss reduction through actual mass of air supplied</u></b></p> <p>Actual mass of air supplied before WHR = 19.74 kg/kg of oil</p> <p>Actual mass of air supplied AFTER WHR = 16.45 kg/kg of oil</p> <p>Existing oil consumption per hour = 25 ton/hr x 60kg/ton = 1500 kg of oil /hr</p> <p>Flue gas loss before WHR = <math>[1500 \text{ kg oil} + (1500 \times 19.74 \text{ kg air})] \times 0.24 \times (600 - 30)</math></p> $= 4255848 \text{ kcal/hr}$ <p>Flue gas loss after WHR = <math>[1500 \text{ kg oil} + (1500 \times 16.45 \text{ kg air})] \times 0.24 \times (300 - 30)</math></p> $= 1696140 \text{ kcal/hr}$ <p>Flue gas heat loss reduction after WHR implementation = <math>4255848 - 1696140</math></p> $= \mathbf{2559708 \text{ kcal/hr}}$ <p>Reduction in fuel oil consumption after installing Waste heat recovery and reduction in excess air = <b>256 kg/hr</b></p> <p>Furnace efficiency after WHR = <math>\frac{25000 \times 0.12 \times (1200 - 40)}{100}</math></p>

	$[(1500-256) \times 10000]$ $= 28 \%$
	<p><b>b) <u>Calculate fuel oil reduction after charging hot ingot in reheating furnace</u></b></p> <p>Ingot charging temperature is increased from 40°C to 500°C</p> <p>Fuel oil reduction due to increased charge temperature =</p> $= 25 \times 1000 \times 0.12 \times (500-40) / 0.28 \times 10,000$ $= 492.86 \text{ kg/hr} = 493 \text{ kg/hr}$
	<p><b>c) <u>Specific oil and power consumption after implementing both the above measure</u></b></p> <p>Fuel oil <b>reduction</b> after implementation of both measures</p> $= 256 + 493 = 749 \text{ kg oil/hr}$ <p>Fuel oil <b>consumption</b> after implementation of both measures</p> $= 1500 - 749 = 751 \text{ kg oil/hr}$ <p>Yield improvement = 3%</p> <p>Production after implementation of both measures = <math>25 \times 1.03 = 25.75 \text{ ton/hr}</math></p> <p>Specific oil consumption = <math>751 / 25.75 = 29.2 \text{ kg/Ton}</math></p> <p>Specific power consumption = <math>25 \times 90 / 25.75 = 87.37 \text{ kWh/ton}</math></p>

----- End of Section - III -----