

**15<sup>th</sup> NATIONAL CERTIFICATION EXAMINATION  
FOR  
ENERGY AUDITORS – August, 2014**

**PAPER – 4: Energy Performance Assessment for Equipment and Utility Systems**

**Date: 24.8.2013    Timings: 14:00-16:00 Hrs    Duration: 2 Hrs    Max. Marks: 100**

**Section - I: BRIEF QUESTIONS**

**Marks: 10 x 1 = 10**

- (i) Answer all **Ten** questions
- (ii) Each question carries **One** mark

S-1	Which loss is not considered while evaluating boiler efficiency by “Indirect Method”?
Ans	Blow down loss
S-2	What will be the synchronous speed of a VFD driven 4-pole induction motor operating at 60 Hz ?
Ans	$N_s = 120 \times f/P$ $= 120 \times 60/4 = 1800 \text{ RPM}$
S-3	What is the refrigerant used in a vapour absorption system with lithium bromide as an absorbent?
Ans	Water
S-4	Other than rated kW of motor and the actual power drawn, what other parameter is required to determine the percentage loading of the motor ?
Ans	Motor Efficiency or rated motor efficiency
S-5	Inclined tube manometer is used for measuring gas flow in a duct when the air velocity is very high: True or False?
Ans	False.
S-6	A pump will cavitate if the $NPSH_{available}$ is _____ than the $NPSH_{required}$
Ans	Less
S-7	To determine the effectiveness of the cooling tower, it is required to measure cooling water inlet, outlet and _____ temperatures.
Ans	Ambient Wet bulb
S-8	The ratio of actual heat transfer to the heat that could be transferred by heat exchanger of infinite size is termed as .....

Ans	Effectiveness
S-9	If the unit heat rate of a power plant is 2866 kcal/kWh ,what is the power plant efficiency ?
Ans	$(860/2866) \times 100 = 30 \%$
S-10	The difference between GCV and NCV of hydrogen fuel is Zero: True or False
Ans	False

..... **End of Section - I** .....

**Section - II: SHORT NUMERICAL QUESTIONS**

**Marks: 2 x 5 = 10**

- (i) Answer all **Two** questions
- (ii) Each question carries **Five** marks

<b>L-1</b>	<p>Hot water at 80 °C is used for room heating in a 5 Star hotel for 4 months in a year. About 200 litres per minute of hot water is maintained in circulation with the return temperature at 50 °C. The hot water is generated using a 'hot waste stream', through a Plate Heat Exchanger (PHE). The hot stream enters the PHE in counterflow direction at 95 °C and leaves at 60 °C. The area of the heat exchanger is 22 m<sup>2</sup>.</p> <p>Calculate the LMTD and the overall heat transfer coefficient.</p>
Ans	<p>Heat load, <math>Q = 200 * 60 * (80 - 50) = 360000 \text{ Kcals/hr (or) } 418.7 \text{ kW}</math></p> $\text{LMTD (for counter flow)} = \frac{(95 - 80)/(60 - 50)}{\ln (15/10)} = 3.7 \text{ }^\circ\text{C}$ <p>Overall Heat Transfer Coefficient, <math>U = Q/( A \times \text{LMTD})</math></p> $= 418.7/(22 \times 3.7) = 5.14 \text{ kW/m}^2 \cdot ^\circ\text{C}$ <p>(OR)</p> $= 4420.4 \text{ kcal/hr.m}^2 \cdot ^\circ\text{C}$
<b>L-2</b>	<p>A gas turbine generator is delivering an output of 20 MW in an open cycle with a heat rate of 3440 kcal/kWh. It is converted to combined cycle plant by adding heat recovery steam generator and a steam turbine raising the power generation output to 28 MW. However, with this retrofitting and increased auxiliary consumption, the fuel consumption increases by 3% in the gas turbine.</p> <p>Calculate the combined cycle gross heat rate and efficiency.</p>

Ans	Gas turbine output	= 20 MW
	Combined cycle output	= 28 MW
	Heat rate in GT open cycle for 20 MW	= 3440 kcal/kwh
	Increase in fuel consumption in combined cycle operation	= 3%
	Combined cycle heat rate	= (3440 X 1.03) X( 20 / 28) = 2530.8 kcal/kwh
	Combined cycle plant efficiency	= (860 / 2530.8) X 100 = 33.98%

..... **End of Section - II** .....

**Section - III: LONG NUMERICAL QUESTIONS**

**Marks: 4 x 20 = 80**

(i) Answer all **Four** questions


<b>N-1</b>	<p>The steam requirement of an export oriented unit is met by a 6 TPH oil fired package boiler generating steam at 10 kg/cm<sup>2</sup>. The monthly steam consumption of the unit is 3000 tonnes.</p> <p>Other data are given below:</p> <p style="margin-left: 20px;">Fuel oil composition: Carbon = 86%; Hydrogen = 12%; Oxygen= 0.5%; Sulphur =1.5%</p> <p style="margin-left: 20px;">Specific heat of flue gases, Cp = 0.27 kcal/kg°C G.C.V. of fuel oil = 10,000 kcal/kg Sp.heat of super heated water vapour = 0.45 kcal/kg°C Enthalpy of steam at 10 kg/cm<sup>2</sup> = 665kcal/kg Feed water temperature = 85 °C % O<sub>2</sub> in dry flue gas = 6% Flue gas temperature at boiler outlet = 240 °C Ambient temperature = 30°C Cost of fuel oil = Rs.43 per kg. Radiation and other unaccounted losses = 2.45%</p> <p>The export oriented unit is costing its steam cost based on the fuel consumption cost with additional 10% to account for the auxiliary and consumables.</p> <p>A neighbouring continuous process plant now offers to supply the required steam at 10 kg/cm<sup>2</sup> to the export oriented unit at a cost of Rs 3300 per tonne.with a condition that all the condensate will be returned back.</p>
------------	--

	<p>Calculate the following:</p> <p>a) Boiler efficiency  b) Cost advantage per tonne of availing steam from neighbouring plant in place of in-house generation and also monthly monetary saving.</p>
<p>Ans</p>	<p><u>First calculate the efficiency of Boiler (in EOU)</u></p> <p>Theoretical air required =  = 11.6 C + 34.8 (H – O/8) + 4.35 S  = [11.6 X 86 + 34.8 (12 – 0.5/8) + 4.35 X 1.5] x 1/100  = 14.195 = Say 14.2</p> <p>% Excess Air = [% O<sub>2</sub> / (21 - % O<sub>2</sub>)] X 100  = [6 / (21 – 6)] X 100 = 40%</p> <p>AAS = Actual amount of air supplied = 14.2 X 1.4  = <b>19.88 kg per kg. of fuel oil</b></p> <p>Mass of dry flue gas m<sub>dfg</sub> = Mass of combustion gases due to presence of C,H,S  +Mass of N<sub>2</sub> supplied  = (0.86 X 44/12) + (0.015 X 64 / 32) + [(19.88 – 14.2) X 23 / 100] + (19.88 X 77/100)  = 19.797</p> <p>Mass dry flue gas ,say = 19.8 Kg / kg fuel  Or  Alternatively mass of dry flue gas = (AAS + 1) – 9 H  = (19.88 + 1) – 9 X 0.12 = 19.8 Kg./Kg. fuel</p> <p>L1 = % heat loss in dry flue gas = [m<sub>dfg</sub> x Cp x (T<sub>q</sub> – T<sub>a</sub>) / GCV] x 100  = <math>\frac{19.8 \times 0.27 \times (240 - 30)}{10,000} \times 100</math>  L1 = <b>11.23%</b></p> <p>L2 = Loss due to presence of hydrogen forming water vapour  <math>\frac{9 \times H [584 + Cps (T_g - T_a)]}{GCV} \times 100</math>  = <math>\frac{9 \times 0.12 [584 + 0.45 (240 - 30)]}{10000} \times 100</math>  L2 = <b>7.33%</b></p> <p>L3 = Radiation and other unaccounted losses = <b>2.45%</b></p> <p>Total losses = L1 + L2 + L3  = 11.23 + 7.33 + 2.45 = <b>21.05 %</b></p> <p>Efficiency of the EOU boiler by indirect method  = 100 – 21.05 = <b>78.99 %</b></p>

	<p style="text-align: center;"><b>= Say 79 %</b></p> <p><u>Secondly calculate the cost of steam in the EOU plant</u></p> <p>Evaporation Ratio = <math>[(n \times GCV) / (h_g - h_f)] \times 100</math>          = <math>[(0.79 \times 10000) / (665 - 85)] \times 100</math>  <b>= 13.62 kg Steam / kg. Fuel</b></p> <p>Fuel oil consumption = 1000 / 13.62 kg. per tonne of steam          Fuel oil consumption = 73.42 kg./tonne of steam gen</p> <p>Cost of fuel oil. = Rs. 43 per kg          Cost of steam in EOU = Fuel cost + 10% fuel cost          = 73.42 x 1.10 x 43          = Rs.3472.8 per tonne</p> <p>Selling cost of steam from neighboring plant = Rs 3300 per tonne</p> <p>Cost advantage = 3472.8 – 3300 = Rs.172.8 per tonne</p> <p>Annual Savings = Rs.172.8 per tonne x 3000tonne/month X 12 month  <b>= Rs.62.2 Lacs</b></p>															
<b>N-2</b>	<p><b>a)</b> The operating parameters of a Vapour Compression Refrigeration system are indicated below.</p> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="padding: 5px;">Parameter</th> <th style="padding: 5px;">Chiller side</th> <th style="padding: 5px;">Condenser side</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">Water Flow (m<sup>3</sup>/hr)</td> <td style="padding: 5px;">89</td> <td style="padding: 5px;">87</td> </tr> <tr> <td style="padding: 5px;">Inlet Temperature (°C)</td> <td style="padding: 5px;">12.2</td> <td style="padding: 5px;">33.3</td> </tr> <tr> <td style="padding: 5px;">Outlet Temperature (°C)</td> <td style="padding: 5px;">8.9</td> <td style="padding: 5px;">37.6</td> </tr> <tr> <td style="padding: 5px;">Density (kg/m<sup>3</sup>)</td> <td style="padding: 5px;">1000</td> <td style="padding: 5px;">990</td> </tr> </tbody> </table> <p>Find the COP of the Refrigeration system ignoring heat losses.</p> <p><b>b)</b> A 6 pole, 415 volt, 3 Φ, 50 Hz induction motor delivers 22 kW power at rotor shaft at a speed of 950 rpm with PF of 0.9. The total loss in the stator including core, copper and other losses, is 2 kW. Calculate the following.</p> <p>i) Slip          ii) Rotor Copper Loss          iii) Total Input to motor          iv) Line current at 415 V and motor pf of 0.9          v) Motor operating efficiency</p>	Parameter	Chiller side	Condenser side	Water Flow (m <sup>3</sup> /hr)	89	87	Inlet Temperature (°C)	12.2	33.3	Outlet Temperature (°C)	8.9	37.6	Density (kg/m <sup>3</sup> )	1000	990
Parameter	Chiller side	Condenser side														
Water Flow (m <sup>3</sup> /hr)	89	87														
Inlet Temperature (°C)	12.2	33.3														
Outlet Temperature (°C)	8.9	37.6														
Density (kg/m <sup>3</sup> )	1000	990														
<b>Ans</b>	<p><b>a)</b> Refrigeration Effect = 89 x 1000 x (12.2 – 8.9)  <b>= 293700 kcal/hr</b></p> <p>Condenser load = 87 x 990 x (37.6 – 33.3)  <b>= 370359 kcal/hr</b></p>															

Compressor work	= Condenser load – Refrigeration effect = 370359 – 293700 = <b>76659 Kcal/hr</b>
C.O.P.	= Refrigeration Effect/ Compressor work = 293700/76659 = <b>3.83</b>
b) Synchronous Speed	= (120 x 50 / 6 ) = 1000 rpm
Motor Speed	= 950 rpm
(i) Slip	= (1000 – 950 ) / 1000 = <b>5 %</b>
Power input to rotor	= { ( 22 / ( 1 – 0.05 ) ) } = 23.16 kW
(ii) Rotor Copper Loss	= ( 0.05 x 23.16 ) = <b>1.158 kW</b>
<b>Or</b>	= 23.16 - 22 = 1.16 kW
(iii) Total Input to motor	= ( 23.16 + 2 ) = <b>25.16 kW</b>
(iv) Line Current	= ( 25.16 x 1000 ) / (√3 x 415 x 0.9 ) = <b>38.86 Amps</b>
(v) Motor Efficiency	= ( 22 / 25.16 ) = <b>87.44 %</b>

**N-3** A common plant facility is installed to provide steam and power to textile and paper plant with a co-generation system. The details and operating parameters are given below:




Other data:

- Turbine, alternator and other losses = 8%
- Specific steam consumption in paper industry= 5 Tons/Ton of paper
- Specific power consumption in paper industry= 550 kWh/Ton of paper

Calculate:

- Coal consumption in boiler per hour or per day.
- Power generation from co-generation plant
- If 10% is auxiliary power consumption in co-generation plant, how much power

	<p>is consumed by the textile industry per hour?</p> <p>iv. What is the gross heat rate of turbine?</p>
Ans	<p>i) Boiler efficiency = Steam production ( steam enthalpy- Feed water enthalpy) / Quantity of coal x G.C.V. of coal  Quantity of coal = 60,000 (810-80)/ 0.8 x 5000  = <b>10.95 tons/hr.</b></p> <p>ii) Gross power generation from co-generation plant</p> <p>Total enthalpy input to turbine = 60,000 x 810 = 48.6 Million kcal.  Total enthalpy out put through back pressure= 60,000* 660 = 39.6 Million kcal  Enthalpy difference = 48.6- 39.6 = 9 Million kcal/hr  Turbine, alternator and other losses =8% or 9x0.08 = 0.72 Million kcal/hr  Useful energy for power generation = 9- 0.72 = 8.28 Million kcal/hr  Power generation from co-generation plant = 8.28 x 10<sup>6</sup>/860 = <b>9628kWh</b></p> <p>iii) If 10% is auxiliary power consumption in co-generation plant, power consumed by textile industry</p> <p>10% of total power generation = 9628 x 0.10 = 962.8kWh</p> <p>Total power consumed by industries = 9628 – 962.8 = 8665.2kWh</p> <p>Total steam consumption in paper plant 40 tons/hr. and specific steam consumption 5 ton/ton of paper. So Paper production per hour is 8 tons.</p> <p>Specific power consumption = 550 kWh/ton.  Total power consumption in paper industry = 8 x 550 = 4400kWh  Total power consumption in textile industry = 8665.2- 4400 = <b>4265.2 kWh</b></p> <p>iv) Gross heat rate= Input enthalpy – output enthalpy/ gross generation  =( 48.6- 39.6) 10<sup>6</sup>/ 9628 = <b>934.7 kCal/kWh</b></p>
<b>N-4</b>	To attempt <b>ANY ONE OF THE FOLLOWING</b> among A, B, C and D
<b>A</b>	A captive thermal plant is delivering an output of 29 MW at the generator terminal. The generator efficiency is 96%. The steam generated in a utility boiler with an efficiency of 86% at 105 ata and 485°C is fed to the turbine. The turbine exhausts steam to condenser maintained at 0.1 ata and 45.5°C. The feed water temperature at inlet to the boiler is 105°C.



The other data pertaining to captive power plant are,

- Enthalpy of steam at 105 ata 485°C = 795 kcal/kg.
- Dryness fraction of steam at inlet to condenser = 0.9
- Enthalpy of dry saturated steam at 0.1ata = 618 kcal/Kg.
- Enthalpy of water at 0.1 ata & at 45.5°C = 45.5 kcal/Kg.
- Loss in the gear box connecting turbine and generator = 1100 kW
- Enthalpy of feed water at inlet to the boiler , = 105 kcal/Kg.

Based on the above data determine:

- i. Output of the steam turbine in kW
- ii. Steam flow through the turbine
- iii. Turbine heat rate
- iv. Unit heat rate

Ans

Enthalpy of steam at turbine exhaust  
i.e.  $h_3$  =  $45.5 + 0.9 (618 - 45.5)$   
= 560.75 Kcal/Kg.

Generator electric output = 29000 KW  
Generator input =  $29000 / 0.96 = 30208.33$  KW

Loss in gear box = 1100 KW  
Output of steam turbine = Generator input + Gear box loss  
=  $30208.33 + 1100$   
= 31308.33 KW

i) Output of the steam turbine **Say = 31308 KW**

ms = Steam flow through turbine



	$= \frac{\text{Turbine output} \times 860}{(h_2 - h_3) \text{ Turbine enthalpy drop}}$ $h_2 = \text{Enthalpy at turbine inlet} = 795 \text{ kcal/kg}$ $h_3 = \text{Enthalpy at turbine exhaust} = 560.75 \text{ kcal/Kg.}$ $m_s = 31308 \times 860 / (795 - 560.75) = 114940.78 \text{ kg/Hr.}$ $= 114.94 \text{ TPH}$ <p>ii) Steam flow through the turbine <b>Say = 115 TPH</b></p> <p>iii) Turbine heat rate = Heat input to turbine / Generator output  <math>= [m_s (h_2 - h_1)] / 29000</math>  <math>= 115000 (795 - 105) / 29000</math>  <math>= 2736.2 \text{ kcal/ kWh}</math></p> <p>iv) Unit heat rate = Turbine heat rate / Efficiency of boiler  Unit heat rate = <math>2736.2 / 0.86 = 3181.63 \text{ kcal/ kWh}</math></p>
	Or
<b>B</b>	<p>In a textile unit a stenter is delivering 80 meters/min of dried cloth at 5% moisture. The moisture of wet cloth at inlet is 50%. The stenter is heated by steam at 7 kg/cm<sup>2</sup> with inlet enthalpy of 660 kcal/kg. and condensate exits the stenter at 105 kcal/kg.</p> <p>Other data</p> <ul style="list-style-type: none"> <li>• Latent heat of water evaporated from the wet cloth = 540 kcal/kg</li> <li>• Weight of 10 meters of dried cloth = 1 kg</li> <li>• Inlet temperature of wet cloth = 27°C</li> <li>• Outlet temperature of dried cloth at stenter outlet = 80°C.</li> </ul> <p>i) Estimate the steam consumption in the stenter considering a dryer efficiency of 48%.</p> <p>ii) Determine the specific steam consumption kg/kg of dried cloth</p>
Ans	<p>Output of stenter = 80 mts/min.  <math>= 80 \times 60 / 10 = 480 \text{ Kg/hr.}</math></p> <p>Moisture in the dried output cloth = 5%  Wt of bone dry cloth = <math>480 \times (1 - 0.05)</math>  i.e. W = 456 Kg/hr.</p> <p><math>m_o</math> = moisture in outlet cloth  <math>= (480 - 456) / 456 = 0.0526 \text{ Kg./Kg. of bone dried cloth}</math></p> <p>Inlet moisture = 50%  Wt of inlet cloth = <math>456 / (1 - 0.50) = 912 \text{ Kg./hr.}</math></p> <p><math>m_i</math> = moisture in inlet cloth  <math>= 912 \times 0.5 / 456 = 1.00 \text{ Kg./Kg. bone dried cloth}</math></p> <p>Inlet temperature of cloth = 27°C  Final temperature of cloth = 80°C</p>

	<p>Heat load on the dryer = <math>w \times (m_i - m_o) \times [(T_{out} - T_{in}) + 540]</math> Kcal/hr.</p> <p>Heat load on the dryer = <math>456 (1 - 0.0526) \times [(80 - 27) + 540]</math> = 2,56,184.5 Kcal/hr</p> <p>Efficiency of the dryer = 48%</p> <p>Heat input to the stenter = <math>2,56,184.5 / 0.48 = 5,33,717.71</math> Kcal/hr</p> <p>Steam consumption in the stenter = <math>5,33,717.71 / (660 - 105)</math> = 961.7 Kg/hr</p> <p>Steam consumption per Kg. of dried cloth at stenter outlet cloth = <math>961.7 / 480</math> = 2 Kg./Kg. dried cloth</p>
	Or
<b>C</b>	<p>Determine the <b>cooling load</b> of a commercial building for the following given data.</p> <p><u>Outdoor conditions :</u> DBT = 35°C ; WBT = 25°C; Humidity = 18 g of water / kg of dry air</p> <p><u>Desired indoor conditions :</u> DBT = 25.6°C ; RH = 50 %; Humidity = 10 g of water / kg of dry air</p> <p>Total area of wall = 40 m<sup>2</sup> Total area of window = 20m<sup>2</sup> U – Factor ( Wall ) = 0.33 W / m<sup>2</sup>K U – Factor ( Roof ) = 0.323 W / m<sup>2</sup>K U – factor [ fixed windows with aluminum frames and a thermal break ] = 3.56 W / m<sup>2</sup>K</p> <ul style="list-style-type: none"> <li>• 15 m x 25 m roof constructed of 100 mm concrete with 90 mm insulation &amp; steel decking.</li> <li>• CLTD at 17:00 h :Details : Wall = 12°C Roof = 44°C Glass Window = 7°C</li> <li>• SCL at 17 : 00 h :Details : Glass Window = 605 W/ m<sup>2</sup></li> <li>• Shading coefficient of Window = 0.74</li> <li>• Space is occupied from 8:00 to 17:00 h by 25 people doing moderately active work.</li> <li>• Sensible heat gain / person = 75 W ; Latent heat gain / person = 55 W ; CLF for people = 0.9</li> <li>• Fluorescent light in space = 21.5 W/m<sup>2</sup> FLF for lighting = 0.9</li> </ul>

	<ul style="list-style-type: none"> <li>• Ballast factor details = 1.2 for fluorescent lights &amp; 1.0 for incandescent lights</li> <li>• Computers and office equipment in space produces 5.4 W/m<sup>2</sup> of sensible heat</li> <li>• One coffee maker produces 1050 W of sensible heat and 450 W of latent heat.</li> <li>• Air changes / hr of infiltration = 0.3</li> <li>• Height of building = 3.6 m</li> </ul>
<p>Ans</p>	<p><b>I External Heat Gain</b></p> <p>(i) Conduction heat gain through the wall = <math>U - \text{factor} \times \text{net area of wall} \times \text{CLTD}</math>  <math>= [0.33 \times 40 \times 12] = 158.4 \text{ W}</math></p> <p>(ii) Conduction heat gain through the roof = <math>U - \text{factor} \times \text{net area of roof} \times \text{CLTD}</math>  <math>= 0.323 \times (15 \times 25) \times 44 = 5329.5 \text{ W}</math></p> <p>(iii) Conduction heat gain through the windows = <math>U - \text{factor} \times \text{net area of windows} \times \text{CLTD}</math>  <math>= (3.56 \times 20 \times 7) = 498.4 \text{ W}</math></p> <p>(i) Solar radiation through glass = <math>\text{Surface area} \times \text{Shading coefficient} \times \text{SCL}</math>  <math>= (20 \times 0.74 \times 605) = 8954 \text{ W}</math></p> <p><b>II Internal Heat Gain</b></p> <p>(i) Heat gain from people = <math>\text{Sensible heat gain} + \text{Latent heat gain}</math></p> <p>Sensible heat gain = <math>(\text{No. of people} \times \text{Sensible heat gain / person} \times \text{CLF})</math>  <math>= (25 \times 75 \times 0.9) = 1687.5 \text{ W}</math></p> <p>Latent heat gain = <math>\text{No. of people} \times \text{Latent heat gain / person}</math>  <math>= (25 \times 55) = 1375 \text{ W}</math></p> <p>Therefore, Heat gain from people = <math>(1687.5 + 1375) = 3062.5 \text{ W}</math></p> <p>(ii) Heat gain from lighting = <math>(\text{Energy input} \times \text{Ballast factor} \times \text{CLF})</math></p> <p>Energy input = <math>(\text{Amount of lighting in space / unit area}) \times \text{Floor area}</math>  <math>= 21.5 \times (15 \times 25) = 8062.5 \text{ W}</math></p> <p>Therefore, heat gain from lighting = <math>(8062.5 \times 1.2 \times 0.9) = 8707.5 \text{ W}</math></p> <p>(iii) Heat generated by equipment :</p> <p>Sensible heat generated by coffee maker = 1050 W          Latent heat generated by coffee maker = 450 W</p>

Sensible heat gain by computers and office equipment =  $5.4 \times 375 = 2025 \text{ W}$

Therefore, Heat generated by equipment = **3 525 h**

(iv) Heat gain through air infiltration = (Sensible heat gain + Latent heat gain)

Sensible heat gain =  $(1210 \times \text{airflow} \times \Delta T)$

Airflow =  $(\text{Volume of space} \times \text{air change rate}) / 3600$

=  $\{ (15 \times 25 \times 3.6) \times 0.3 \} / 3600$

=  $0.1125 \text{ m}^3 / \text{s}$

Therefore, sensible heat gain =  $1210 \times 0.1125 \times (35 - 25.6) = 1 279.58 \text{ W}$

Latent heat gain =  $3010 \times 0.1125 \times (18 - 10) = 2 709 \text{ W}$

No	Space Load Components	Sensible Heat Load (W)	Latent Heat Load (W)
1	Conduction through exterior wall	158.4	-----
2	Conduction through roof	5 329.5	-----
3	Conduction through windows	498.4	-----
4	Solar radiation through windows	8954	-----
5	Heat gained from people	1 687.5	1 375
6	Heat gained from lighting	8 707.5	-----
7	Heat gained from equipment	3 075	450
8	Heat gained by air infiltration	1 279.58	2 709
<b>Total space cooling load</b>		<b>29 689.88</b>	<b>4 534</b>

Or

**D** During heat balance of a 5 stage preheater Kiln in a cement plant, the following data was measured at Preheater (PH) Fan Inlet and clinker cooler vent air fan inlet:

Parameter measured	Temperature	Static Pressure	Avg. Dynamic Pressure	Specific heat	Gas Density at STP	Duct Area
Unit	°C	(P <sub>s</sub> ) mm WC	(P <sub>d</sub> ) mm WC	kcal/kg °C	kg/m <sup>3</sup>	m <sup>2</sup>
PH Exit Gas at PH fan Inlet	316	-650	28.6	0.248	1.4	2.27
Clinker cooler vent air at cooler Stack Fan Inlet	268	-56	9.7	0.24	1.29	2.01

Note: take Pitot tube constant as 0.85, reference temperature 20 °C and atmospheric pressure 9908 mm WC.

	<p>Other Data</p> <table border="1" data-bbox="365 262 1377 415"> <thead> <tr> <th>Clinker Production</th> <th>Designed specific volume of PH gas</th> <th>NCV of Coal</th> <th>Cost of coal</th> <th>Annual Operation</th> </tr> <tr> <th>TPH</th> <th>Nm<sup>3</sup>/kg clinker</th> <th>kcal/kg</th> <th>Rs./ton</th> <th>hrs</th> </tr> </thead> <tbody> <tr> <td>45.16</td> <td>1.75</td> <td>5500</td> <td>5500</td> <td>8000</td> </tr> </tbody> </table> <p>Calculate the following:</p> <ol style="list-style-type: none"> <li>Specific volume of PH gas as well as cooler vent air (Nm<sup>3</sup>/kg clinker)</li> <li>Heat loss in pre-heater exit gas (kcal/kg clinker)</li> <li>Heat loss in cooler vent air (kcal/kg clinker)</li> <li>If the measured specific volume of PH gas (Nm<sup>3</sup>/kg clinker) exceeds the design value, calculate the heat loss (kcal/kg clinker) and annual monetary loss due to excessive specific volume of PH gas.</li> </ol>	Clinker Production	Designed specific volume of PH gas	NCV of Coal	Cost of coal	Annual Operation	TPH	Nm <sup>3</sup> /kg clinker	kcal/kg	Rs./ton	hrs	45.16	1.75	5500	5500	8000
Clinker Production	Designed specific volume of PH gas	NCV of Coal	Cost of coal	Annual Operation												
TPH	Nm <sup>3</sup> /kg clinker	kcal/kg	Rs./ton	hrs												
45.16	1.75	5500	5500	8000												
<p>Ans</p>	<ol style="list-style-type: none"> <li>Density of Pre-heater gas at PH Fan Inlet at prevailing temp., pressure conditions:           <math display="block">\rho_{T,P} = \rho_{STP} \times \frac{273 \times (9908 + P_s)}{(273 + T) \times 10334}</math> <math display="block">\rho_{T,P} = 1.40 \times \frac{273 \times (9908 - 650)}{(273 + 316) \times 10334} = 0.581 \text{ kg/m}^3</math> <p>Velocity of PH gas</p> <math display="block">v = P_t \sqrt{\frac{2gP_d}{\rho_{T,P}}}</math> <math display="block">v = 0.85 \sqrt{\frac{2 \times 9.8 \times 28.6}{0.581}} = 26.4 \text{ m/sec}</math> <p>Volumetric flow rate of PH gas = velocity X duct cross-sectional area</p> <math display="block">= 26.4 \times 2.27</math> <math display="block">= 59.9 \text{ m}^3/\text{sec}</math> <math display="block">= 59.9 \times 3600</math> <math display="block">= 215640 \text{ m}^3/\text{hr}</math> <p>Specific volume of PH gas = 215640 X 0.58/1.4</p> <math display="block">= 89491 \text{ Nm}^3/\text{hr}</math> <math display="block">= 89491/45160 = \mathbf{1.98 \text{ Nm}^3/\text{kg clinker}}</math> <p>Similarly density of cooler vent air at cooler vent air fan Inlet at prevailing temp., pressure conditions:</p> <math display="block">\rho_{T,P} = \rho_{STP} \times \frac{273 \times (9908 + P_s)}{(273 + T) \times 10334}</math> </li> </ol>															

$$\rho_{T,P} = 1.29 \times \frac{273 \times (9908 - 56)}{(273 + 268) \times 10334} = 0.62 \text{ kg/m}^3$$

Velocity of cooler vent air in the fan inlet duct

$$v = P_t \sqrt{\frac{2gP_d}{\rho_{T,P}}}$$

$$v = 0.85 \sqrt{\frac{2 \times 9.8 \times 9.7}{0.62}} = 14.88 \text{ m/sec}$$

Volumetric flow rate of PH gas = velocity X duct cross-sectional area  
 = 14.88 X 2.01  
 = 29.9 m<sup>3</sup>/sec  
 = 29.9 X 3600  
 = 107640 m<sup>3</sup>/hr

Specific volume of cooler vent air = 107640 X 0.62/1.29  
 = 51734 Nm<sup>3</sup>/hr  
 = 51734/45160 = **1.15 Nm<sup>3</sup>/kg clinker**

ii) Heat loss in PH exit gas

$$Q1 = m_{ph} c_p \Delta T \quad (C_p \text{ of PH gas} = 0.248 \text{ kcal/kg } ^\circ\text{C})$$

$$Q1 = 1.98 \times 1.4 \times 0.248 \times (316 - 20) = \mathbf{203.5 \text{ kcal/kg clinker}}$$

iii) Heat loss in cooler vent air

$$Q2 = m_{CA} c_p \Delta T \quad (C_p \text{ of cooler vent air} = 0.24 \text{ kcal/kg } ^\circ\text{C})$$

$$Q2 = 1.15 \times 1.29 \times 0.24 \times (268 - 20) = \mathbf{88.3 \text{ kcal/kg clinker}}$$

iv) Heat Loss due to excess specific volume of PH gas

$$V_{\text{excess}} = 1.98 - 1.75 = 0.23 \text{ Nm}^3/\text{kg clinker}$$

$$\text{Heat loss } Q = 0.23 \times 1.4 \times 0.248 \times (316 - 20) = 23.6 \text{ kcal/kg clinker}$$

Equivalent coal saving = 23.6/5500 = 0.0043 kg coal/kg clinker or ton of coal/ton of clinker

Coal saving in one hour = 0.0043 x 45.16 = 0.194 TPH

Annual Coal Saving = 0.194 x 8000 = 1552 tons of coal per annum

**Annual Monetary Saving = 1552 x 5500 = Rs. 85.36 lakhs**

----- End of Section - III -----